

From: [Will Gorrod](#)
To: [Planning Services](#)
Subject: FUL/2021/0015 Aldeby Solar Park - EHO Consultation Response
Date: 09 September 2021 11:19:18

WARNING: External email, think before you click!.

Dear Ralph,

Firstly apologies for the late consultation response.

Having reviewed the documentation submitted on the planning explorer I would like to see a detailed noise assessment from the applicant. The environmental statement identifies the inverters as being a source of noise but as far as I can see there is no accompanying noise assessment or noise modelling associated with this. I would like to see a noise assessment/modelling undertaken to quantify the impact of operations against nearby receptors.

Apart from noise, I am largely happy with the application. I would however recommend the use of a construction management plan condition as well as a condition detailing the applicants responsibilities if any previously unknown contaminated land is discovered during construction. I will reply formally with these conditions once I've received and reviewed a noise assessment.

Lastly, I am happy with the proposed concrete footings in areas identified as lacking substantial capping depth for penetrative foundations.

Please get in touch if you require any further details.

Kind regards

Will Gorrod

Environmental Management Officer

[e wgorrod@s-norfolk.gov.uk](mailto:wgorrod@s-norfolk.gov.uk)

This email and any attachments are intended for the addressee only and may be confidential. If they come to you in error you must take no action based on them, nor must you copy or show them to anyone. Please advise the sender by replying to this email immediately and then delete the original from your computer. Unless this email relates to Broadland District Council or South Norfolk Council business it will be regarded by the council as personal and will not be authorised by or sent on behalf of the councils. The sender will have sole responsibility for any legal actions or disputes that may arise. We have taken steps to ensure that this email and any attachments are free from known viruses but in keeping with good computing practice, you should ensure they are virus free. Emails sent from and received by members and employees of Broadland District Council and South Norfolk Council may be monitored.