

via e-mail

Ralph Cox
Planning Services, Floor 6
Norfolk County Council
County Hall
Martineau Lane
Norwich
Norfolk
NR1 2SG

NCC contact number: 0344 800 8020
Text relay no.: 18001 0344 800 8020

Your Ref: FUL/2021/0015
Date: 13 January 2022

My Ref: FW2021_1086
Tel No.: 0344 800 8020
Email: llfa@norfolk.gov.uk

Dear Ralph,

Town and County Planning (Development Management Procedure) (England) Order 2015

Installation of a solar photovoltaic array/solar park with associated infrastructure at Aldeby: Aldeby landfill site, Common Road, Aldeby, Beccles, NR34 0BL

Thank you for your consultation on the above site, received on 15 December 2021.

I can confirm that the County Council as Lead Local Flood Authority has no comments to make.

Informative:

Details provided on the Site Layout Plan drawing (Arcus, Drawing Ref: 3757-REP-005, Dated 25 October 2021) illustrate that an inverter or a DNO Switching station has been placed in an area mapped as being at high risk of surface water flooding. Environment Agency Surface Water flood risk mapping illustrates that this area of the site is at risk of flooding from 3.33% annual probability flood (AEP) rainfall events and higher.

Yours sincerely

Mark Ogden

Flood and Water Manager
Community Services and Environment
Lead Local Flood Authority