



From: webmaster@norfolk.gov.uk
Sent: 24 June 2024 10:37
To: Planning Services
Subject: New comments for application FUL/2024/0025

Categories: BSA

New comments have been received for application FUL/2024/0025 from

Comments:

We note there are overhead cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

In the instance of overhead cables within the vicinity, GS6 (Advice on working near overhead powerlines) and a safety visit is required by UK Power Networks. Information and applications regarding GS6 can be found on our website <https://www.ukpowernetworks.co.uk/safety-equipment/power-lines/working-near-power-lines/advice-on-working-near-overhead-power-lines-gs6#Apply>

Should any diversion works be necessary because of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.

You can also find support and application forms on our website [Moving electricity supplies or equipment | UK Power Networks](#)