

From: webmaster@norfolk.gov.uk
Sent: 25 March 2024 11:00
To: Planning Services
Subject: New comments for application FUL/2024/0001

Categories: BSA

New comments have been received for application FUL/2024/0001 from [REDACTED]

Comments:

Please note there are EHV and HV cables on the site running within close proximity to the proposed development. Prior to commencement of work accurate records should be obtained from our Plan Provision Department at UK Power Networks, Fore Hamlet, Ipswich, IP3 8AA.

All works should be undertaken with due regard to Health & Safety Guidance notes HS(G)47 Avoiding Danger from Underground services. This document is available from local HSE offices.

Should any diversion works be necessary as a result of the development then enquiries should be made to our Customer Connections department. The address is UK Power Networks, Metropolitan house, Darkes Lane, Potters Bar, Herts, EN6 1AG.